## TYPE P2BPAGFP AUTOMATIC CONTROL BOX

## IP65 - D.O.L. Starters for 0.5-2.0HP Single Phase Pumps

# For dirty water and sewage applications.





#### **FEATURES**

**BOX:** Strong thermoplastic enclosure (IP65) hinged to left hand side and double locks to right. Clear thermoplastic front panel. 4 x wall mounting brackets

#### **INNER STEEL HINGED LID:**

Amber Light = Mains supply.

Green Light = Pump running.

Upper Red Light = High level alarm.

Lower Red Light = Thermal cut-out.

Door Interlocking Isolator

Hand-Off-Auto Switch.

Audible alarm buzzer.

Alarm on/off switch.

**INTERNALS:** 50VA Transformer: To reduce 230V supply to 24Vac for level control safety.

Plug-In Relay: For level controls.
Contactor with Overload: Manual setting for pump running Amps.
Fuses: Fuse holders with HRC fuses on mains and auxiliary circuits.
Facility for pump starting capacitor.

Designed for the control and running of 230V single phase pumps, offering protection against dry running and motor overload. Suitable for submersible pumps with motor sizes up to a nominal 13 Amps.

| MODEL    | AMPS                         | DIM. CM      | WEIGHT |
|----------|------------------------------|--------------|--------|
|          | MIN/MAX (Ranges)             | H x W x D    | KG     |
| P2BPAGFP | 2.5/13.0 2.5-4 / 4-6 / 5.5-8 | 50 x 30 x 22 | 11.3   |


#### **OPERATION**

In operation, the level control system utilises float switches operating on 24Vac. Normally three float switches are required; one upper (high level alarm), one middle (start) and one lower (stop).

### TYPICAL SUMP EMPTYING APPLICATION

When the sump liquid level rises, it triggers the middle or 'start' float switch. As the liquid level falls to the set point, it triggers the lower float switch, turning the pump off. If for any reason the pump does not start and/or the liquid level rises to the top float switch, the audible alarm is triggered and the alarm indicator light on the panel is illuminated.

As a guide, it is recommended that the pump cycle should not be repeated more than 6 times per hour. In a filling application, the cycle is simply reversed.



© Descriptions, technical data and features contained in this leaflet are not binding. We reserve the right to make any necessary modifications without prior notice.

